



DECLARATION OF PERFORMANCE NO. FS-SP1910-05 Rev.1 EN

Unique identification code of the product-type	Art. Nos. 100918-100919, 100921 - 100936
Product name:	Fire Box
Intended use:	Fire stopping and fire sealing: Penetration Seals
Manufacturer:	FireSeal AB Esbogatan 14 SE-164 74 Kista SWEDEN
System of AVCP:	SYSTEM 1
European Assessment Document:	EAD 350454-00-1104, September 2017
European Technical Assessment:	ETA-21/0196 (2021-04-23)
Technical Assessment Body:	ETA-Danmark A/S (TAB)
EC Certificate (Certificate of Constancy of Performance):	2821-CPR-0175 (2022-03-16) (Notified Body UL nr. 2821)

Essential Characteristics	Declared Performance	Harmonised Technical Specification
Safety in case of fire		
Reaction to fire	NPD	
Resistance to fire	EI 30/ EI 45/ 60/ EI 90/ EI 120	EN 13501-2 See ETA-21/0196 Annex A
Hygiene, health and environment		
Air permeability	NPD	
Water permeability	NPD	
Content, emission and/or release of dangerous substances	Use categories: IA1	Declaration of manufacturer
Safety in use		
Mechanical resistance and stability	NPD	
Resistance to impact/movement	NPD	




The fireseal system originally developed to safeguard nuclear power plants

FireSeal AB
Esbogatan 14, 164 74 Kista
Box 7091, SE-16407 Kista, Sweden
+46(0) 8 623 61 60
www.fireseal.se



Adhesion	NPD	
Durability	Y2 (-5/+70 °C)	EOTA TR 024: 2009
Protection against noise		
Airborne sound insulation	NPD	
Energy economy and heat retention		
Thermal properties	NPD	
Water vapour permeability	NPD	

NPD = No Performance Determined

An electronic copy of this declaration of performance and ETA-21/0196 is available for download at https://fireseal.se/produkts/fire-box/	
--	--


This declaration of performance replaces previous issued FS-SP1910-05 dated 2020-11-04

The performance of the product identified above is in conformity with the set of declared performances. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above:

For fire resistance, installation and configuration, see ETA-21/0196 dated 2021-04-23

Signed for and on the behalf of the manufacturer by:

Kista Sweden, 2022-03-23


Anders Wigant
Product Manager